

Licence Holder : Neatport Pty Ltd
ABN : 62 063 770 534
Trading Name : Suncoast Waste Water Management
Licence No : SMK02608
Licence Status : Certified



[View PDF Certificate](#)

Standard(s) Number : AS/NZS 1546.3:2008 **Standard(s) Title :** On-site domestic wastewater treatment units - Aerated wastewater treatment systems
 AS 1546.3:2017 On-site domestic wastewater treatment units - Secondary treatment systems
Originally Certified : 15 Aug 2001 **Issued Date :** 30 Jun 2021
Currently Certified : 29 Jun 2021 **Expires :** 14 Aug 2026

Site Details :

| State | Country |
|-------|-----------|
| QLD | Australia |

Product Details :

Standard - AS/NZS 1546.3:2008 On-site domestic wastewater treatment units - Aerated wastewater treatment systems

| Model Name | Model ID. | No. of Persons | System Capacity | System Type | Treatment Method | Disinfection Method | Service Interval | Comments / Exclusions | Date Endorsed |
|----------------------------|-----------|----------------|---|-------------------------------------|------------------|---------------------|---|---|---------------|
| OZZI KLEEN | RP-10 | 10 | 4150 L tank design capacity. Treatment capacity 2000L/day. | Aerated Wastewater Treatment System | Aeration | Chlorine | 3 months or as specified by state regulators. | | 15 Aug 2001 |
| OZZI KLEEN | RP-10A+ | 10 | 4150 L tank design capacity. Treatment capacity 2000L/day. | Aerated Wastewater Treatment System | Aeration | Chlorine | 3 months or as specified by state regulators. | With Alum dosing unit for nutrient reduction. | 20 Dec 2016 |

Standard - AS 1546.3:2017 On-site domestic wastewater treatment units - Secondary treatment systems

AS 1546.3:2017 has no products defined